

NOT TO SCALE

NOTES:

- 1. VARIANCES TO BUFFERS (WIDTH OR TYPE) MUST BE APPROVED BY THE TOWN BOARD.
- 2. SITE LAYOUT (BOTH PUMP STATION AND PAVED ACCESS ROAD) REQUIRE APPROVAL OF DIRECTOR OF PUBLIC UTILITIES DEPT.
- 3. WET WELL AND GRINDER MH TO BE TREATED WITH SPECTRASHIELD.

ELECTRICAL RISER (SEE DETAIL)
 THE CONTROL PANEL SHALL CONFORM WITH THE TOWN OF FUQUAY VARINA SCADA SPECIFICATION IN ORDER TO INTEGRATE THE STATION INTO THE TOWN'S SCADA SYSTEM IN THE FUTURE.

12.5'x7' CONCRETE PAD

TRANSFORMER (SEE ELECTRICAL DRAWINGS)

ON DEMAND HEATER
 (MIN. 20 GPM WITH A TEMP. DIFFERENCE OF 15° F)

EFFECTIVE: DECEMBER 10, 2021

